

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS TEST REPORT

Sample From: **Nkangala District Municipality** Address: Posbus 437
Municipal Health Services **Walter Sisulu**
Emakhazeni Town Council **Middelburg**
1050

Date Received: **27-Jul-17**
Date Analyzed: **27-Jul-17**
Date Reported: **29-Jul-17**
Quantity Analyzed: **1**

Ref No: **G 1417 / 17 B**

LAB NO		SAMPLE NAME	STERILIZED BOTTLE		STANDARD LIMITS				
					≤ 10	Nil	Nil	≤ 1000	
					TOTAL COLIFORM BACTERIA PER / 100ML	FAECAL COLIFORM PER / 100 ML	ESCHERISCHIA COLIFORM PER 100 ML	HETEROTROPHIC PLATE COUNT PER 1.0 ML	
	BF	BELFAST	YES	NO		A / B			
G 1417	15/17/17	Belfast Old Age Home	x		Nil	B	-	Nil	38
					A- SANAS 5221 OR B - COLILERT	SANS 5221	COLILERT	SANS 5221	

S.A.N.S. 241-1:2015 Ed 2 MICROBIOLOGICAL REQUIREMENTS Allowable compliance for *DRINKING WATER*

Determinant	Risk	Unit	Standard limits
Escherichia Coliform / or Faecal Coliform bacteria	Acute Health - 1	Count per 100 ml	Not Detected
Heterotrophic Plate Count	Operational	Count per 1 ml	≤ 1 000
Total Coliform Bacteria	Operational	Count per 100 ml	≤ 10

Results exceeding alert levels will require immediate remedial action and follow-up sampling.

EFFLUENT WATER

Regional Standard (Department Water Affairs and Forestry) of 26 March 2004 No.399 for Waste water specifies : Waste water or Effluent shall **not** contain more than 1000 Faecal Coliform per 100 ml.

These results relate only to samples tested.
Opinions and interpretations expressed herein are outside the scope of SANAS accreditation.
- Samples highlighted in grey are not within the limits as specified.

REMARKS:



P.L.G UYS (M.D.)
Technical Signatory

SANS
241-1
Edition 2
2015